



NOTES:

1. SNOWSHELF MAY BE REDUCED TO 6' IN AREAS WITHOUT SIDEWALK.
2. HORIZONTAL AND VERTICAL SEPARATION TO MEET STATE PUBLIC HEALTH CODE.
3. PROVIDE EASEMENT FOR METAL BEAM RAIL AS REQUIRED FOR 6" MIN. SEPARATION FROM BACK OF SIDEWALK.

1 1/2" BITUMINOUS CLASS 2
2" BITUMINOUS CLASS 1
4" PROCESSED STONE BASE
10" GRAVEL SUBBASE

SEE NOTE 2

1' (TYP.)

METAL BEAM RAIL
LOCATED BEHIND
SIDEWALK, SEE NOTE 3

CL&P, AT&T, COX
IN COMMON TRENCH
(30" MIN. COVER)

SIDE SLOPES
4:1 TYPICAL
2:1 MAX.

SCALE : NONE

DRAWN BY: SR

CHECKED BY: SMB

APPROVED BY: DAP

LAST REVISED:

9/2/2008



TOWN OF GLASTONBURY
DEPARTMENT OF PHYSICAL SERVICES
ENGINEERING DIVISION

LIMITED LOCAL STREET
TYPICAL SECTION
(0-200 ADT)

PLATE NO. 1A